


- NOTES:**
1. ROOF HATCH COLOR SCHEDULE
BELOW ROOF PLATFORM: MATCH TANK
ABOVE ROOF PLATFORM: SAFETY YELLOW
 2. ALL ROOF HATCH HARDWARE SHALL BE 316 STAINLESS STEEL.
 3. HINGE SHALL PERMIT FULL 180°+ OPENING OF ROOF HATCH LID.
 4. PROVIDE SLIP-RESISTANT GALVANIZED STEEL PLATE OR SOLID-TOP GRATING AROUND PERIMETER OF HATCH FRAME, FLUSH WITH SURROUNDING PLATFORM GRATING SURFACE. PANELS SHALL NOT EXCEED 50 LBS. EACH, TO FACILITATE REMOVAL.
WIDTH SHALL BE:
4'-0" ON ACCESS SIDE OF HATCH
1'-0" ON ALLOTHER SIDES OF HATCH
 5. HATCH SHALL BE ORIENTED WITH HINGE SIDE TOWARD TANK PERMETER AND ACCESS SIDE TOWARD TANK CENTER.

SQUARE ROOF HATCH

REVISIONS						APPROVALS			EASTERN MUNICIPAL WATER DISTRICT STANDARD DRAWING	
NO.	DATE	INITIAL	DESCRIPTION	APP'D	DATE		INITIAL	DATE		
						DESIGN	AGA	8/16/12	 EASTERN MUNICIPAL WATER DISTRICT	
						CONSTRUCTION	MJ	8/29/12		
2	10/10/24	GS	REVISED NOTES, REMOVED DIMENSION CALL OUT AND ADDED LIMIT SWITCH, LOCKING HASP WITH SECURITY COVER	CRC	10/10/24	INSPECTION	CD	8/29/12		
						OPERATIONS	KG	8/28/12		
1	7/18/23	AMZ	INCREASED HATCH SIZE; REMOVED FALL PROTECTION GRATING	CRC	7/18/23	SUBMITTED	GK	8/14/12		
REFERENCES:				SCALE: NONE		RECOMMENDED			EASTERN MUNICIPAL WATER DISTRICT STEEL TANK ROOF HATCH	
FILE I.D.: J:\Master CAD Files - Restricted\B-984.dgn				DRAWN BY: SL		Joe Mouawad DIRECTOR OF ENGINEERING 8/15/12 DATE			APPROVED Charlie J. Bachmann ASSISTANT GENERAL MANAGER 8/29/12 DATE	

B-984

