


**NOTES:**

1. THE CONTRACTOR SHALL PROVIDE A MINIMUM 12" LAP OF STEEL PLATE ON EACH SIDE OF TRENCH TO ASSURE NO SLIPPING OF PLATE OR COLLAPSING OF TRENCH WALL. WHERE 12" LAP CANNOT BE MET, ENGINEER DESIGN REQUIRED.
2. MULTIPLE PLATES MUST BE TACK WELDED AS NEEDED TO SECURE PLATES, 6" MIN.
3. ALL PLATES MUST MEET REQUIRED TRAFFIC LOADS.

**TYPICAL TRENCH PLATE DETAIL**

N.T.S.

**TO BE IMPLEMENTED ON ALL EMWD PROJECTS**

REVISIONS				APPROVALS				EASTERN MUNICIPAL WATER DISTRICT STANDARD DRAWING	
NO.	DATE	INITIAL	DESCRIPTION	APP'D	DATE	INITIAL	DATE		
2	5/3/19	GS	UPDATED TITLE BLOCK, FONT AND LOGO	AGA	5/3/19	CM	8/17/05	 EASTERN MUNICIPAL WATER DISTRICT	
1	8/25/05	CM	CHANGE FONT OF TEXT	VJB	8/26/05	CONSTRUCTION			
						INSPECTION	CD 8/17/05		
						OPERATIONS			
						SUBMITTED	VJB 8/17/05		
REFERENCES:				SCALE: NONE		RECOMMENDED _____		APPROVED <u>C.J. Bachmann</u> 8/24/05	
FILE I.D.: \kauai\eng\std dwgs\B-934.dgn				DRAWN BY: KER					
								<b>B-934</b>	