



NOTES:

1. ROOF HATCH COLOR SCHEDULE
BELOW ROOF PLATFORM: MATCH TANK
ABOVE ROOF PLATFORM: SAFETY YELLOW
2. ALL ROOF HATCH HARDWARE SHALL BE 316 STAINLESS STEEL.
3. HINGE SHALL PERMIT FULL 180°+ OPENING OF ROOF HATCH LID.
4. PROVIDE SLIP-RESISTANT GALVANIZED STEEL PLATE OR SOLID-TOP GRATING AROUND PERIMETER OF HATCH FRAME, FLUSH WITH SURROUNDING PLATFORM GRATING SURFACE. PANELS SHALL NOT EXCEED 50 LBS. EACH, TO FACILITATE REMOVAL.

REVISIONS					
NO.	DATE	INITIAL	DESCRIPTION	APP'D	DATE
1	07/18/23	AMZ	INCREASED HATCH SIZE; REMOVED FALL PROTECTION GRATING	CRC	07/18/23

APPROVALS		
	INITIAL	DATE
DESIGN	AGA	8/16/12
CONSTRUCTION	MM9	8/29/12
INSPECTION	CD	8/29/12
OPERATIONS	KQ	8/28/12
SUBMITTED	GK	8/14/12



EASTERN MUNICIPAL WATER DISTRICT
STANDARD DRAWING

STEEL TANK ROOF HATCH

REFERENCES:	SCALE: NONE
FILE I.D.: kauai\eng\std dwgs\B-984.dwg	DRAWN BY: SL

RECOMMENDED *Joe Mouawad* 8/15/12
DIRECTOR OF ENGINEERING DATE

APPROVED *Charlie J. Bachmann* 8/29/12
ASSISTANT GENERAL MANAGER DATE

B-984