

UPDATE LOG FOR SECTION 04220

Date	Item(s) Changed	Page #
090208	<p>1.01. DESCRIPTION</p> <p>C. Surface Treatment of Unpainted Masonry Structures. Unless otherwise noted, the following surface treatments shall be used. Application to be per the manufacturer's instructions.</p> <p>1. Condition: Below grade surfaces shall be waterproofed with a cold applied waterproofing system consisting of a primer coat covered with not less than three (3) coats of fibrated asphalt emulsion and not less than one (1) layer of 15-lb. asphalt saturated fabric and ½" thick asphalt impregnated protective fiber board. The system shall be "E-M-W Waterproofing System" by Flintkote Co., Bird & Sons or equal.</p> <p>2. Condition: Above grade surfaces shall be treated with a clear waterproofing coating, Rainguard Regular, Rainproof or equal.</p> <p>3. Masonry surfaces shall be clean and dry before applying surface treatment and shall be free of any efflorescence. Masonry surfaces shall cure a minimum of 10 days prior to surface treatment application.</p> <p>C. <u>Waterproofing and/or Water Repellent of Masonry.</u> Masonry surfaces shall be clean and dry before applying surface treatment and shall be free of any efflorescence. Masonry surfaces shall cure for a minimum of 10 days prior to surface treatment application.</p>	1
090208	<p>2.01 <u>MATERIALS.</u></p> <p>J. <u>Waterproofing.</u> Below grade surfaces shall be waterproofed with a pre-fabricated self-adhering sheet type waterproofing membrane. The membrane shall consist of a multi-layer high-strength polymer film that is coated with a rubberized asphalt adhesive. The system shall be MFW SubSeal 40 by Chargar Corporation; or equal.</p> <p>K. <u>Water Repellent.</u> Above grade surfaces shall have a water repellent that is a silane/siloxane, volatile organic compound compliant, and free of silicone oils or paraffin wax. The spray equipment shall be high-volume, low-pressure, airless with a maximum of 60 psi. The pump shall be non-atomizing and able to flow at a rate of 1 to 1-1/2 gallons per minute. The system shall be Rainguard, Blok-Lok; Prosoco Inc.; or equal.</p>	5

Change Legend:

- Added**
- ~~Strike-out~~

Document is prepped for double-sided printing